

Fire Prevention

The likelihood of fire is generally high in connection with construction work due to the work that is in progress and the ever-changing workplace and its organisation. In addition, the possible consequence in the event of fire is severe due to the absence of proper fire compartments, less orderly conditions for evacuation and limited extinguishing equipment.

Organisation and planning

As a supplier to Skanska you must always make sure that the person performing work for you is aware of and follows Skanska's rules or instructions to prevent fire or limit its consequences. This includes instructions and procedures for smoking and performing hot work / flammable work.

You will obtain information from Skanska's production management no later than on arrival at the workplace concerning who is Bas-U, fire safety manager, flammable goods safety supervisor and which person or persons that are appointed permit issuer for hot work / flammable work on site .


The permit issuer, the fire guard and the executor of hot work/ flammable work are all responsible for working according to following procedures.

Planning

- In your Work Instruction you must minimise the risk of fire by when possible chose a work method other than hot work/ flammable work. If unavoidable, a specific permit will be required.
- Report the need for permission for hot work/flammable work in good time.
- Ensure that inspections and maintenance are carried out regularly on fire protection equipment and that this has undergone approved annual inspection prior to being brought to the workplace.
- Store materials and waste that catch fire easy safely and follow Skanska's instructions.
- Plan for the use of a fire guard unless the permit issuer allows for exception.



A trolley to carry the extinguishing equipment facilitates work.



Before work commence

- Valid training certificates for persons who are to perform hot work/flammable work or be fire guards must be submitted to the Bas-U/Permit Issuer no later than in conjunction with the start of the work .
- Information regarding flammable goods, including handling instructions and requirements, shall be submitted to Bas-U/ flammable goods safety supervisor as early as possible and always prior to arrival at the workplace.

Safe execution

- Hot work/flammable work must not be carried out without the permission of the Permit Issuer. Permits are granted and followed up at the relevant workplace.
- If the conditions for the current permit are changed, the work shall be discontinued.
- As a supplier, you must provide extinguishing equipment for your work when carrying out hot work/flammable work. The equipment shall be labelled with the supplier's company name.